

On April 13, 2013, Board Member Chuck Shaw asked the following question regarding Board Meeting 4/17/2013 Agenda Item: FS-2 Pahokee High School Project Modification. A response is provided below.

Question: I understand from a visit to the school a couple of years ago that steel issues are widespread in that site. Is that accurate and how much will this handle?

Response: Due to the corroded columns, we have Jay Ammon, architect, doing an envelope study on the entire school. His report, due in two to three weeks, will give us a more accurate picture of the entire issue. The immediate project is to replace the very worst corroded, shored up columns (18 of 52) holding up exterior walkways at buildings #1, #2, and #3, with some contingency to replace other somewhat corroded columns on campus.

Kristin Garrison, AICP
Director, Planning & Real Estate Services
[561-357-7573](tel:561-357-7573)